



CORRIGENDUM - 1
TENDER No_AGL/0317/TO/CNG CASCADE/08-19

Techno-Commercial Queries

Sr.no.	Clause No./Document No.	Page no.	Tender Description	Bidder's Query	AGL Reply/Remarks
1	Tender Document- Clause No. 8.1 of Technical Specification	Page 31 of 106	Size of Cascade	Size of cascade shall be as :3000ltr.- L x W x H – 5500mm x 2100mm x 2100mm,4500ltr. L x W x H – 5500mm x 2100mm x 2100mm, without canopy. Size of cascade shall be as per cascade drawings	Tender Condition Prevails
2	Tender Document- Clause No. 8.3 of Technical Specification	Page 33 of 106	Piping / Tubing / Fitting/ Pressure gauges	All SS fittings including valves shall be of Swagelok / Parker. Material shall be SS 316 conforming to ASTM A269/A182/A276. Open ends on fittings and vents shall be provided with caps. Kindly arrange to include M/s. Dk-Lok as per attached credential	Accepted.
3	Tender Document- Clause No. 8.3 of Technical Specification	Page 33 of 106	Piping / Tubing / Fitting/ Pressure Gauges	All end connections quick release coupling etc shall be within temper proof wire cage enclosure. The enclosure shall be made of metal sheet box with transparent plastic sheet for visibility.	All end connection for PG , TG etc , valves & fittings shall be within Tamper proof wire cage enclosure except QRC.
4	Tender Document- Clause No. 8.5 of Technical Specification	Page 33 of 106	Mandatory Spares (NOT REQUIRED)	Mandatory Spares (NOT REQUIRED) (Not required)- does it mean not to supply?	yes, your understanding is correct.
5	Tender Document IFB Point 4	Page 4 of 106	Delivery Period	Delivery period from the date of Each Delivery Order (DO) - 8 Weeks. Delivery period will 16 weeks from date of receipt of DO. For 1st Lot 16 weeks from date of receipt of DO along with Approved Drawing & QAP	Tender Condition Prevails

This Corrigendum-1 forms an integral part of the Tender Document No.: AGL/0317/TO/CNG CASCADE/08-19 and a copy (duly signed and stamped) of the same is to be submitted along with the Bid.